

|   |   |  |  |   |
|---|---|--|--|---|
| <b>Prüfbericht-Nr.:</b><br>Test report no.:   | CN23AYBH 001  | <b>Auftrags-Nr.:</b><br>Order no.:   | 168447779                                | Seite 1 von 38<br>Page 1 of 38  |
| <b>Kunden-Referenz-Nr.:</b><br>Client reference no.:  | 2544823   | <b>Auftragsdatum:</b><br>Order date:   | 2023-05-15                               |   |
| <b>Auftraggeber:</b><br>Client:   | Discover Energy Systems corp.<br>#7-13511 Crestwood Place, Richmond, BC V6V 2E9 Canada  |  |  |   |
| <b>Prüfgegenstand:</b><br>Test item:  | Energy Storage System   |  |  |   |
| <b>Bezeichnung / Typ-Nr.:</b><br>Identification / Type no.:   | 950-0053_6  |  |  |   |
| <b>Auftrags-Inhalt:</b><br>Order content:   | Test report   |  |  |   |
| <b>Prüfgrundlage:</b><br>Test specification:  | UL 9540A: 2019 (Fourth Edition)   |  |  |   |
| <b>Wareneingangsdatum:</b><br>Date of sample receipt:   | 2023-10-17  |  |  |   |
| <b>Prüfmuster-Nr.:</b><br>Test sample no.:  | Engineering samples   |  |  |   |
| <b>Prüfzeitraum:</b><br>Testing period:   | 2023-10-17 - 2023-10-20   |  |  |   |
| <b>Ort der Prüfung:</b><br>Place of testing:  | See to clause 1.1 of main report  |  |  |   |
| <b>Prüflaboratorium:</b><br>Testing laboratory:   | See to clause 1.1 of main report  |  |  |   |
| <b>Prüfergebnis*:</b><br>Test result*:  | See main report   |  |  |   |
| <b>erstellt von:</b><br>created by:   | <br>Jason Zhu<br>Project Engineer  |  | <b>genehmigt von:</b><br>authorized by:  | <br>Xun Yu<br>Reviewer |
| <b>Datum:</b><br>Date:  | 2024-01-08  |  | <b>Ausstellungsdatum:</b><br>Issue date: | 2024-01-08  |
| <b>Stellung / Position:</b>   | Project Engineer  |  | <b>Stellung / Position:</b>              | Reviewer  |
| <b>Sonstiges / Other:</b>   | <p>This report is based on previous report CN23PVP9 001. The changes as follow:<br/>1. The Client name and address are changed.<br/>2. The model number are changed.<br/>In addition to the above changes, no additional tests needed.</p> <p>This report does not evidence compliance of the provided sample with the relevant standards but only with the referred tests. This test report documents the findings of examination conducted on the delivered product mentioned above only. This report does not entitle the applicant to carry any safety mark on this or similar products. Further for sales or other application purposes of the tested product, any reference to TÜV Rheinland or a test through TÜV Rheinland is only permissible with prior written consent of TÜV Rheinland.</p> |  |  |   |
| <b>Zustand des Prüfgegenstandes bei Anlieferung:</b><br>Condition of the test item at delivery:   | Prüfmuster vollständig und unbeschädigt<br>Test item complete and undamaged   |  |  |   |
| * Legende:  | P(ass) = entspricht o.g. Prüfgrundlage(n)   | F(ail) = entspricht nicht o.g. Prüfgrundlage(n)                                      | N/A = nicht anwendbar                    | N/T = nicht getestet  |
| * Legend:   | P(ass) = passed a.m. test specification(s)  | F(ail) = failed a.m. test specification(s)   | N/A = not applicable                     | N/T = not tested  |
| <p><b>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.</b><br/>This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</p> |   |  |  |   |

Prüfbericht-Nr.: CN23AYBH 001  
Test report no.:

Seite 2 von 38  
Page 2 of 38

**Anmerkungen**  
*Remarks*

|   |  |
|---|--|
| 1 | <p>Alle eingesetzten Prüfmittel waren zum angegebenen Prüfzeitraum gemäß eines festgelegten Kalibrierungsprogramms unseres Prüfhauses kalibriert. Sie entsprechen den in den Prüfprogrammen hinterlegten Anforderungen. Die Rückverfolgbarkeit der eingesetzten Prüfmittel ist durch die Einhaltung der Regelungen unseres Managementsystems gegeben.<br/>Detaillierte Informationen bezüglich Prüfkonditionen, Prüfequipment und Messunsicherheiten sind im Prüflabor vorhanden und können auf Wunsch bereitgestellt werden.</p> <p><i>The equipment used during the specified testing period was calibrated according to our test laboratory calibration program. The equipment fulfils the requirements included in the relevant standards. The traceability of the test equipment used is ensured by compliance with the regulations of our management system. Detailed information regarding test conditions, equipment and measurement uncertainty is available in the test laboratory and could be provided on request.</i></p>   |
| 2 | <p>Wie vertraglich vereinbart, wurde dieses Dokument nur digital unterzeichnet. Der TÜV Rheinland hat nicht überprüft, welche rechtlichen oder sonstigen diesbezüglichen Anforderungen für dieses Dokument gelten. Diese Überprüfung liegt in der Verantwortung des Benutzers dieses Dokuments. Auf Verlangen des Kunden kann der TÜV Rheinland die Gültigkeit der digitalen Signatur durch ein gesondertes Dokument bestätigen. Diese Anfrage ist an unseren Vertrieb zu richten. Eine Umweltgebühr für einen solchen zusätzlichen Service wird erhoben. Informationen zur Verifizierung der Authentizität unserer Dokumente erhalten Sie auf folgender Webseite: <a href="http://go.tuv.com/digital-signature">go.tuv.com/digital-signature</a></p> <p><i>As contractually agreed, this document has been signed digitally only. TÜV Rheinland has not verified and unable to verify which legal or other pertaining requirements are applicable for this document. Such verification is within the responsibility of the user of this document. Upon request by its client, TÜV Rheinland can confirm the validity of the digital signature by a separate document. Such request shall be addressed to our Sales department. An environmental fee for such additional service will be charged. For information on verifying the authenticity of our documents, please visit the following website: <a href="http://go.tuv.com/digital-signature">go.tuv.com/digital-signature</a></i></p> |
| 3 | <p>Prüfklausel mit der Note * wurden an qualifizierte Unterauftragnehmer vergeben und sind unter der jeweiligen Prüfklausel des Berichts beschrieben.<br/>Abweichungen von Prüfspezifikation(en) oder Kundenanforderungen sind in der jeweiligen Prüfklausel im Bericht aufgeführt.</p> <p><i>Test clauses with remark of * are subcontracted to qualified subcontractors and described under the respective test clause in the report.<br/>Deviations of testing specification(s) or customer requirements are listed in specific test clause in the report.</i></p>  |
| 4 | <p>Die Entscheidungsregel für Konformitätserklärungen basierend auf numerischen Messergebnissen in diesem Prüfbericht basiert auf der "Null-Grenzwert-Regel" und der "Einfachen Akzeptanz" gemäß ILAC G8:2019 und IEC Guide 115:2021, es sei denn, in der auf Seite 1 dieses Berichts genannten angewandten Norm ist etwas anderes festgelegt oder vom Kunden gewünscht. Dies bedeutet, dass die Messunsicherheit nicht berücksichtigt wird und daher auch nicht im Prüfbericht angegeben wird. Zu weiteren Informationen bezüglich des Risikos durch diese Entscheidungsregel siehe ILAC G8:2019.</p> <p><i>The decision rule for statements of conformity, based on numerical measurement results, in this test report is based on the "Zero Guard Band Rule" and "Simple Acceptance" in accordance with ILAC G8:2019 and IEC Guide 115:2021, unless otherwise specified in the applied standard mentioned on Page 1 of this report or requested by the customer. This means that measurement uncertainty is not taken in account and hence also not declared in the test report. For additional information to the resulting risk based of this decision rule please refer to ILAC G8:2019.</i></p>   |

## INTRODUCTION

Model fire codes and energy storage system standards require energy storage systems to comply with UL 9540, which in turn requires battery cells and modules to comply with UL 1973. Compliance with these standards reduces the risk of batteries and battery energy storage systems (BESS) creating fire, shock or personal injury hazards. However, they don't evaluate the ability of the BESS installed as intended and with fire suppression mechanisms in place if necessary, from contributing to a fire or explosion in the end use installations.

To address these fire and explosion hazards associated with the installation of a BESS, the fire and other codes require energy storage systems to meet certain location, separation, fire suppression and other criteria. Those codes also provide a means to provide an equivalent level of safety based on large scale fire testing of anticipated BESS installations.

UL 9540A is intended to provide a test method that can be used as a basis for validating the safety of a BESS installation in lieu of meeting the specific criteria provided in those codes. The data generated can be used to determine the fire and explosion protection required for installation of a BESS.

The test method is initiated through the establishment of a thermal runaway condition that leads to combustion within the BESS. The test method outlined in UL 9540A consists of several steps – cell level testing, module level testing, unit level testing and installation level testing. The cell and module level testing steps are information gathering steps to inform the unit and installation level testing.

The following outlines the information that may be gathered as part of the testing:

- a) Cell level – An individual cell fails in a manner that leads to thermal runaway and fire through a suitable method such as external heating. Data such as off-gassing contents, temperatures at venting and temperatures at thermal runaway are recorded.
- b) Module level – One or more cells within a BESS module fail in the manner determined during the cell level testing. Data such as fire propagation in the module, temperatures on the failed cells and surrounding cells, off-gassing contents and heat release data are gathered.
- c) Unit level – A complete BESS is installed surrounded by target (e.g. dummy) BESS and walls separated at a distance as intended in its installation. The module level test is repeated on a module located in the BESS in the most unfavorable location. Data such as temperature within the BESS, on surrounding walls and target BESS; incident heat flux on walls and target BESS; observation of fire propagation from BESS to target units and walls as well as observance of explosions or evidence of re-ignition within the BESS; and heat release and off-gassing contents are gathered.
- d) Installation level – This test is a repeat of the unit level test with the test conducted within a test room and with the intended fire suppression system installed as well as any overhead cables (that can lead to fire propagation) installed. This test is intended to validate the fire suppression system for the BESS installation. Data such as temperature within the BESS, on surrounding walls and target BESS; incident heat flux on walls and target BESS; fire propagation from the BESS to target units, walls or overhead cables and any observable explosion incidents or re-ignition within the BESS; and off-gassing contents (if needed) and heat release are gathered.

## Contents

|          |   |           |
|----------|---|-----------|
| <b>1</b> | <b>GENERAL INFORMATION .....</b>                                | <b>5</b>  |
| 1.1      | TEST SPECIFICATION .....  | 5         |
| 1.2      | GENERAL REMARKS .....   | 5         |
| 1.3      | REVISION INFORMATION .....                                      | 5         |
| 1.4      | DEFINITIONS .....   | 6         |
| <b>2</b> | <b>GENERAL PRODUCT INFORMATION .....</b>                        | <b>7</b>  |
| 2.1      | CELL .....  | 7         |
| 2.2      | MODULE .....  | 8         |
| 2.3      | UNIT .....  | 9         |
| 2.4      | PHOTO.....  | 10        |
| <b>3</b> | <b>UNIT LEVEL TEST (SECTION 9 OF UL 9540A) .....</b>            | <b>11</b> |
| 3.1      | GENERAL .....   | 11        |
| 3.2      | UNIT SAMPLE PREPARATION .....                                   | 12        |
| 3.3      | SETUP OF THE TEST .....   | 12        |
| 3.3.1    | <i>Battery system installation information</i> .....            | 12        |
| 3.3.2    | <i>Test site setup</i> .....                                    | 13        |
| 3.3.3    | <i>Thermal runaway setup</i> .....                              | 14        |
| 3.4      | OBSERVATIONS AND RECORDS .....                                  | 17        |
| 3.5      | TEMPERATURE MEASUREMENT .....                                   | 18        |
| 3.5.1    | <i>Temperature measurement of initiating module</i> .....       | 18        |
| 3.5.2    | <i>Temperature measurement of modules surface in unit</i> ..... | 20        |
| 3.5.3    | <i>Temperature measurement of instrumented wall</i> .....       | 21        |
| 3.6      | HEAT FLUX MEASUREMENT .....                                     | 22        |
| 3.7      | CHEMICAL HEAT RELEASE RATE MEASUREMENT .....                    | 23        |
| 3.8      | CONVECTIVE HEAT RELEASE RATE MEASUREMENT .....                  | 25        |
| 3.9      | SMOKE RELEASE RATE MEASUREMENT .....                            | 26        |
| 3.9.1    | <i>Test method</i> .....  | 26        |
| 3.9.2    | <i>Test result</i> .....  | 26        |
| 3.10     | GAS GENERATION MEASUREMENT .....                                | 27        |
| 3.10.1   | <i>Test method</i> .....  | 27        |
| 3.10.2   | <i>Total gas release</i> .....                                  | 27        |
| 3.10.3   | <i>Gas components</i> .....                                     | 27        |
| 3.11     | PERFORMANCE SUMMARY REMARK AGAINST CRITERIA .....               | 29        |
| 3.12     | PHOTOS .....  | 30        |
| 3.13     | LIST OF TEST AND MEASUREMENT INSTRUMENTS .....                  | 37        |

# 1 General information

## 1.1 Test specification

**Standard: ANSI/CAN/UL 9540A: 2019 (Fourth Edition)**

**Test Method for Evaluating Thermal Runaway Fire Propagation in Battery Energy Storage Systems**

This report presents the result of unit level tests of UL 9540A: 2019.

All tests were conducted at TUV Rheinland (Shenzhen) Co., Ltd. and TUV Rheinland's partner labs that were under supervision of TÜV Rheinland's engineer.

Testing period: 2023-10-17 to 2023-10-20

Refer to Clause 4 for test and measurement instruments.

## 1.2 General remarks

This report is descriptive and provide the test data only.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the testing laboratory.

Throughout this report a  comma /  point is used as the decimal separator.

## 1.3 Revision information

New report, not applicable.

## 1.4 Definitions

**CELL** – The basic functional electrochemical unit containing an assembly of electrodes, electrolyte, separators, container, and terminals. It is a source of electrical energy by direct conversion of chemical energy.

**MODULE** – A subassembly that is a component of a BESS that consists of a group of cells or electrochemical capacitors connected together either in a series and/or parallel configuration (sometimes referred to as a block) with or without protective devices and monitoring circuitry.

**UNIT** – A frame, rack or enclosure that consists of a functional BESS which includes components and subassemblies such as cells, modules, battery management systems, ventilation devices and other ancillary equipment.

**BATTERY SYSTEM (BS)** – Is a component of a BESS and consists of one or more modules typically in a rack configuration, controls such as the BMS and components that make up the system such as cooling systems, disconnects and protection devices.

**BATTERY ENERGY STORAGE SYSTEM (BESS)** – Stationary equipment that receives electrical energy and then utilizes batteries to store that energy to supply electrical energy at future time. The BESS, at a minimum consists of one or more modules, a power conditioning system (PCS), battery management system (BMS) and balance of plant components.

a) **INITIATING BATTERY ENERGY STORAGE SYSTEM UNIT (INITIATING BESS)** – A BESS unit which has been equipped with resistance heaters in order to create the internal fire condition necessary for the installation level test.

b) **TARGET BATTERY ENERGY STORAGE SYSTEM UNIT (TARGET BESS)** – The enclosure and/or rack hardware that physically supports and/or contains the components that comprise a BESS. The target BESS unit does not contain energy storage components, but serves to enable instrumentation to measure the thermal exposure from the initiating BESS.

**Note:** Depending upon the configuration and design of the BESS (e.g. the BESS is composed of multiple separate parts within separate enclosures), the unit level test can be done at battery system level. In such case, the BESS is be read as BS throughout this report.

**NON-RESIDENTIAL USE** – Intended for use in commercial, industrial or utility owned locations.

**RESIDENTIAL USE** – In accordance with this standard, intended for use in one or two family homes and town homes and individual dwelling units of multi-family dwellings.

**THERMAL RUNAWAY**- The incident when an electrochemical cell increases its temperature through self-heating in an uncontrollable fashion. The thermal runaway progresses when the cell's generation of heat is at a higher rate than the heat it can dissipate. This may lead to fire, explosion and gas evolution.

**STATE OF CHARGE (SOC)** – The available capacity in a BESS, pack, module or cell expressed as a percentage of rated capacity.

## 2 General Product Information

The product information and parameters were provided by the client as below.

### 2.1 Cell

|   |   |
|---|---|
| Manufacturer:                             | <b>Ruipu Energy Co., Ltd.</b><br>No.205, Binhai 6th Road, konggang New District,<br>Longwan District, Wenzhou Zhejiang, P.R. China  |
| Model number:                             | CB27173204EA  |
| Chemistry:                                | <input checked="" type="checkbox"/> LiFePO <sub>4</sub> <input type="checkbox"/> NMC <input type="checkbox"/> NCA <input type="checkbox"/> LTO<br><input type="checkbox"/> Other: |
| Physical configuration:                   | <input checked="" type="checkbox"/> Prismatic <input type="checkbox"/> Cylindrical <input type="checkbox"/> Pouch<br>Weight(kg): 2.1±0.1kg  |
| Electrical rating :                       | Rated capacity (Ah): 100<br>Nominal voltage (V): 3.2  |
| Standard charge method:                   | Charge current (A): 100<br>Standard Charge Voltage (V): 3.65<br>Cut off current (A): 5  |
| Standard discharge method:                | Discharge current (A): 100<br>End of discharge voltage (V): 2.5   |
| Maximum continuous charge current (A):    | 100   |
| Maximum continuous discharge current (A): | 100   |
| Compliance with UL 1973:                  | <input checked="" type="checkbox"/> Yes <u>TUV Rheinland: CN212RU5 001</u><br><input type="checkbox"/> No   |

## 2.2 Module

|                            |   |  |
|----------------------------|---|--|
| Manufacturer:              | <b>Discover Energy Systems corp.</b><br>#7-13511 Crestwood Place Richmond BC V6V 2E9 Canada |  |
| Model number:              | 48-48-5120 / 900-0062, 48-48-5120-H / 900-0067  |  |
| Physical configuration:    | Metal enclosure   |  |
|                            | Weight:   | Approx. 44 kg  |
|                            | Cells in series/parallel:   | 1P16S  |
| Cooling method:            | Air cooling   |  |
| Separation between cells:  | -   |  |
| Electrical rating:         | Rated capacity:   | 100 Ah   |
|                            | Nominal voltage:  | 51.2 Vdc   |
| Standard charge method:    | Charge power:   | 70A  |
|                            | End of charge:  | The highest voltage reaches 55.2V                              |
| Standard discharge method: | Discharge power:  | 70A  |
|                            | End of discharge:   | The lowest voltage reaches 48 V                                |
| Compliance with UL 1973:   | <input checked="" type="checkbox"/> Yes   | <input type="checkbox"/> No <u>TUV Rheinland: CN233MYV 004</u> |

## 2.3 Unit

|   |   |
|---|---|
| Product name  | Energy Storage System   |
| Model   | 950-0053_6  |
| Voltage range   | 48V ~ 55.2V   |
| Nominal voltage   | 51.2 Vdc  |
| Maximum charge Current                                    | 500A  |
| Maximum discharge Current                                 | 500A  |
| Rated capacity  | 600 Ah  |
| Operating Temperature                                     | Charge: 4°C to 52°C<br>Discharge: -17°C to 52°C   |
| Recommend charging method declared by the manufacturer    | Charge at a constant current 420A until voltage reaches 55.2V then charge at constant voltage of 55.2V until charge current is 15A. |
| Recommend discharging method declared by the manufacturer | Discharged with 420A constant current to discharge cut-off voltage 48V  |
| Nominal mass  | 360 kg  |
| External dimensions (mm)                                  | Max. D*L*H: 350*680*1721  |

### Unit diagram with overall dimension




Figure 1. Front





Figure 3. Side




Figure 4. Top

Unit: mm

## 2.4 Photo



Module



Unit

## **3 Unit level test (section 9 of UL 9540A)**

### **3.1 General**

Unit level testing corresponds with the testing anticipated by fire codes and other codes impacting energy storage system installations to evaluate the large scale fire performance of BESS units installed in, on or adjacent to buildings or in other areas and their resultant performance to qualify for exceptions to limits in the codes imposed on these installations. The limitations where exceptions may be sought are limitations on the size of the individual BESS units, the total number of BESS units installed within a room, and the separation distances between BESS units and between BESS units and walls of the building.

In this test the initiating BESS unit is placed a set distance from target BESS units simulating BESS units identical to the initiating BESS unit, and from simulated walls representative on the installation. A thermal runaway is induced in cells, using the same approach as used in the module level testing within one of the modules in the initiating BESS, and a variety of measurements are taken. The results are intended to be used to verify that a fire within a single BESS unit will not spread to other units, nor breach the walls or the BESS enclosure (if provided), and there shall be no flying debris or explosive discharge of gases.

The test arrangement include the largest (energy) BESS unit for the installation to be represented by the test, and minimum spacing to adjacent walls and BESS units. The BESS may be tested with an internal fire suppression system provided by the manufacturer if that fire suppression system is required to be installed in the BESS. Optional internal fire suppression systems are not included in the unit level testing.

The test monitors the fire behavior of the BESS unit and measures heat release rates (convective and chemical); gas generation and composition; smoke release rate; maximum heat flux on the target BESS units, wall surfaces and within the accessible means of egress; maximum surface temperatures of the walls and modules within the target BESS units; and documents any explosions, deflagrations and flying debris from the BESS under test.

### 3.2 Unit sample preparation

The battery system is constructed with 6 modules that was considered as a unit for purposes of the test.

All 6 modules samples through 2 charge/discharge cycles per the manufacturer's instructions to verify that the module was functional. Each cycle was defined as a charge to 100% SOC and allowed to rest 30 minutes and then discharged to an end of discharge voltage (EODV) determined by the module specification. Refer to 2.2 for the end of condition of charge and discharge.

### 3.3 Setup of the test

#### 3.3.1 Battery system installation information

The installation information was provided by the client as below.

|                             |   |   |
|-----------------------------|---|---|
| Intended use location ..... | <input checked="" type="checkbox"/> Residential                     | <input checked="" type="checkbox"/> Non-residential |
|                             | <input checked="" type="checkbox"/> Non-residential rooftop         |   |
|                             | <input checked="" type="checkbox"/> Non-residential open garage use |   |
| Type of installation.....   | <input checked="" type="checkbox"/> Indoor                          | <input checked="" type="checkbox"/> Outdoor         |
|                             | <input checked="" type="checkbox"/> Floor/ground mounted            | <input type="checkbox"/> Wall mounted               |
| Row(s) of installation      | <input checked="" type="checkbox"/> Single                          | <input checked="" type="checkbox"/> Multiple        |

### 3.3.2 Test site setup

Two instrumented wall with 3.66 m height, 4.1 m length. Walls were constructed of 16-mm (5/8-in) gypsum wall board and painted flat black.

Three units were used for the purpose of the test.

The initiating unit was positioned adjacent to the two instrumented wall sections.

Minimum separation distance from the unit to wall and between unit were provided by the client, separation distance: A=B=C=D=G=44.45mm, E=300mm.

Unit's layout can be seen in Figure 1.




Figure 1. Top view of sub-unit's layout

### 3.3.3 Thermal runaway setup

Setup of Unit:

There were three units were marked as initiating unit and target unit, one was initiating unit, and the others were target units. Each unit was installing 6 modules.

Modules 4 in initiating unit was selected as “initiating module” for the test.

Modules 02, 03, 06 in initiating unit and modules in target unit 01 and target unit 02 were used to check the possible propagation between modules in initiating unit and target unit. Figure 2 show the details.




Figure 2. Module numbering in unit




Figure 3. Thermocouple in initiating unit




Figure 4. Thermocouple in target unit 01




Figure 5. Thermocouple in target unit 02

One heater, controlled by a PID heating controller; The PID controller were used to control the voltage supply to the heater and maintain a 4°C/min to 7°C/min heating rate.


The heater was de-energized immediately and independently as the thermal runaway observed on the cell that is heat by the heater.

#### Setup of module:

The module was consisted of 16 cells (1P16S). All cells in the pack were numbered as below picture.


External heating method was used to initiate thermal runaway in the module. One PET heater, rated 220V ac/429 W, size 165 x 200 x 0.33 mm, was fitted on cell.

1 thermocouple, Type K, 24AWG, were attached between the cells and under the heating surface. Temperature of both sides were monitored during test. See Figure 6 to 7 for the detail locations.



Remark: The number 1~16 means Cell #1~#16 distributed in modules.

Figure 6. Internal view of module



Remark: The number 1~10 means Thermocouple no. T1~T10 distributed in modules.

Figure 7. Location of heater and thermocouple

### 3.4 Observations and records

Before test:

The initiating module was charged to 100% SOC and allowed to stabilize for a minimum of 1 h and a maximum of 8 h before the start of the test.

Ambient condition at the initiation of the test was 26.8°C, 60.5% R.H.

Test was performed on 2023.10.19, started at 19:58 PM.

| Before the test, Module 16 in Initiating unit |       |
|---|-------|
| OCV (V)                                       | 52.54 |
| Weight (kg)                                   | 44.45 |

Observations during test:

| Time            | 1           | 2           |
|-----------------|-------------|-------------|
| Vent time       | 20:59:15 PM | 21:01:32 PM |
| Thermal runaway | 21:00:40 PM | 21:02:58 PM |

No flying debris or explosive discharge of gases during test.

No sparks, electrical arcs, or other electrical events during test.

No external flaming was observed.

Observations after test:

No damage on target walls.

No damage on target units.

The initiating cell (cell 14) of Module 04 were damaged (thermal runaway) after the test. Cell 11 was damaged because of the cell to cell propagation.

| After the test, Module 04 in Initiating unit |       |
|--|-------|
| OCV (V)                                      | 45.66 |
| Weight (kg)                                  | 44.05 |
| Weight loss (kg)                             | 0.4   |

### 3.5 Temperature measurement

#### 3.5.1 Temperature measurement of initiating module

Multiple thermocouples, Type K, 24AWG, were attached on all module and unit. See Figure 3 to Figure 6 for the detailed locations.

The thermocouple temperature of the module 04 in initiating unit was shown in the figure 7 as below.




Figure 8. Temperature vs time curve of module 04 in initiating unit.

| Thermocouple no. | Location                                | Maximum temp. °C |
|------------------|---|------------------|
| T1               | Between cell_14 and Heater              | 457.6            |
| T2               | Bottom surface of cell_15               | 284.8            |
| T3               | Top surface of cell_11                  | 480.5            |
| T4               | Top surface of cell_10                  | 281.1            |
| T5               | Top surface of cell_13                  | 84.8             |
| T6               | Top surface of cell_12                  | 89.6             |
| T7               | Bottom surface of cell_16               | 84               |
| T8               | Bottom surface of cell_03               | 64.9             |
| T9               | Back surface of the internal Enclosure  | 285.9            |
| T10              | Right surface of the internal Enclosure | 186.4            |
| T_Ambient        | Ambient temperature                     | 26.8             |

### 3.5.2 Temperature measurement of modules surface in unit




Figure 9. Surface temperatures of module in unit

| Unit            | Channel Number | Location   | Max Temp. (°C) |
|-----------------|----------------|--|----------------|
| Initiating Unit | #1             | Top surface of the Enclosure of module 04          | 91.7           |
|                 | #2             | Front surface of the Enclosure of module 04        | 49.0           |
|                 | #3             | Back surface of the Enclosure of module 04         | 118.9          |
|                 | #4             | Right surface of the Enclosure of module 04        | 113.0          |
|                 | #5             | Left surface of the Enclosure of module 04         | 65.2           |
|                 | #6             | Top surface of the internal Enclosure of module 04 | 120.4          |
|                 | #7             | Bottom surface of the Enclosure of module 04       | 89.5           |
|                 | #8             | Bottom surface of the Enclosure of module 01       | 38.5           |
|                 | #9             | Bottom surface of the Enclosure of module 02       | 38.8           |
|                 | #10            | Right surface of the Enclosure of module 03        | 47.8           |
|                 | #11            | Top surface of the Enclosure of module 05          | 39.2           |
|                 | #12            | Top surface of the Enclosure of module 06          | 65.1           |
| Target unit 01  | D1             | Right surface of the Enclosure of module 01        | 28.3           |
|                 | D2             | Right surface of the Enclosure of module 03        | 28.1           |
|                 | D3             | Right surface of the Enclosure of module 05        | 27.6           |
| Target unit 02  | G1             | Front surface of the Enclosure of module 01        | 31.5           |
|                 | G2             | Front surface of the Enclosure of module 03        | 34.1           |
|                 | G3             | Front surface of the Enclosure of module 05        | 30.8           |

### 3.5.3 Temperature measurement of instrumented wall

Wall surface temperatures were measured in vertical array at 152 mm intervals for the full height of the instrumented wall sections using Type K, 24 AWG thermocouple. The thermocouple array were collinear with the center line of initiating unit and target unit.




Figure 10. Temperature of instrumented wall A and C

| Number | Location  | Channel | Max Temp. (°C) |
|--------|---|---------|----------------|
| 1      | Wall A.<br>Vertical array at 152 mm intervals.<br>Left side of Unit1_sub-unitA in the horizontal direction. | A1~A25  | 32.5           |
| 2      | Wall C.<br>Vertical array at 152 mm intervals.<br>In front of Unit1_sub-unitA in the horizontal direction.  | C1~C25  |                |

### 3.6 Heat flux measurement

Five sensors were placed on the instrument wall A, wall C and target units to measure the heat flux, see below table and figure 10 for details.

| Channel Number | Location  |
|----------------|---|
| HF1, HF2       | on the surface of instrumented wall A                 |
| HF3            | on the surface of instrumented wall C                 |
| HF4            | on target unit 01 surface that facing initiating unit |
| HF5            | on target unit 02 surface that facing initiating unit |




Figure 11. Heat flux sensor layout




Figure 12. The measured heat flux of target walls and target unit

### 3.7 Chemical heat release rate measurement

The chemical heat release rates were measured by an oxygen consumption calorimeter measurement system consisting of a paramagnetic oxygen analyzer, non-dispersive infrared carbon dioxide and carbon monoxide analyzer, velocity probe, and a Type K thermocouple.

The instrumentations are located in the exhaust duct of the heat release rate calorimeter.

The chemical heat release rate was calculated at each of the flows as follows:

$$HRR_1 = \left[ E \times \varphi - (E_{CO} - E) \times \frac{1 - \varphi}{2} \times \frac{X_{CO}}{X_{O_2}} \right] \times \frac{\dot{m}_e}{1 + \varphi \times (\alpha - 1)} \times \frac{M_{O_2}}{M_a} \times (1 - X_{H_2O}^o) \times X_{O_2}^o$$

In which:

$HRR_t$  = total heat release rate, as a function of time (kW)

$E$  = Net heat released for complete combustion per unit of oxygen consumed (adjusted for oxygen contained within cell chemistry, 13,100 kJ/kg)

$E_{CO}$  = Net heat released for complete combustion per unit of oxygen consumed, for CO (adjusted for oxygen contained within cell chemistry, 17,600 kJ/kg)

$\varphi$  = Oxygen depletion factor (non-dimensional), where:

$$\varphi = \frac{X_{O_2}^o \times [1 - X_{CO_2} - X_{CO}] - X_{O_2} \times [1 - X_{CO_2}^o]}{X_{O_2}^o \times [1 - X_{O_2} - X_{CO_2} - X_{CO}]}$$

$X_{CO}$  = Measured mole fraction of CO in exhaust flow (non-dimensional)

$X_{CO_2}$  = Measured mole fraction of CO<sub>2</sub> in exhaust flow (non-dimensional)

$X^{oCO_2}$  = Measured mole fraction of CO<sub>2</sub> in incoming air (non-dimensional)

$X^{oH_2O}$  = Measured mole fraction of H<sub>2</sub>O in incoming air (non-dimensional)

$X_{O_2}$  = Measured mole fraction of O<sub>2</sub> in exhaust flow (non-dimensional)

$X^{oO_2}$  = Measured mole fraction of O<sub>2</sub> in incoming air (non-dimensional)

$\alpha$  = Combustion expansion factor (non-dimensional; normally a value of 1.105)

$M_a$  = Molecular weight of incoming and exhaust air (29 kg/kmol)

$M_{O_2}$  = Molecular weight of oxygen (32 kg/kmol)

$\dot{m}_e$  = Mass flow rate in exhaust duct (kg/s), in which:

$$\dot{m}_e = C \times \sqrt{\frac{\Delta p}{T_e}}$$

or

$$\dot{m}_e = 26.54 \times \frac{A \times k_c}{f(Re)} \times \sqrt{\frac{\Delta p}{T_e}}$$

$C$  = Orifice plate coefficient (in  $\text{kg}^{1/2}\text{m}^{1/2}\text{K}^{1/2}$ )

$\Delta p$  = Pressure drop across orifice plate or bidirectional probe (Pa)

$T_e$  = Combustion gas temperature at orifice plate or bidirectional probe (K)

$A$  = Cross sectional area of the duct ( $\text{m}^2$ )

$k_c$  = Velocity profile shape factor (non-dimensional)

$f(Re)$  = Reynolds number correction (non-dimensional)

Measured peak chemical heat release rate HRR was 2.547 kW




Figure 13. HRR curve

Measured total heat release THR through the test was 2.738 MJ




Figure 14. THR curve

### 3.8 Convective heat release rate measurement

The convective heat release rate were measured using thermopile, a velocity probe, and a Type K thermocouple, located in the exhaust system of the exhaust duct.

The convective heat release rate was calculated at each of the flows as follows:

$$HRR_c = V_e A \frac{353.22}{T_e} \int_{T_o}^T C_p dT$$

Where:

$HRR_c$  = The convective heat release rate (kW)

$V_e$  = The exhaust velocity (m/s)

$A$  = The exhaust duct cross sectional area (m<sup>2</sup>)

$T_e$  = The temperature at the location where exhaust velocity is measured (K)

$353.22/T_e$  = The density of air at the velocity measurement location (kg/m<sup>3</sup>)

$T_o$  = The ambient temperature (K) in the test room

$T$  = The thermopile temperature (K)

$$\int_{T_o}^T C_p dT = A_0(T - T_o) + A_1 / 2(T^2 - T_o^2) + A_2 / 3(T^3 - T_o^3) + A_3 / 4(T^4 - T_o^4)$$

$C_p$  = Specific heat of air (kJ/kg-K), given as  $C_p = A_0 + A_1 T + A_2 T^2 + A_3 T^3$ , where:

$$A_0 = 0.9950$$

$$A_1 = -5.29933E-05$$

$$A_2 = 3.21022E-07$$

$$A_3 = -1.22004E-10$$




Figure 15. HRRc curve

### 3.9 Smoke release rate measurement

#### 3.9.1 Test method

The light transmission in the calorimeter's exhaust duct was measured using a white light source and photo detector for the duration of the test. The smoke release rate was calculated as follows:

The whole smoke release rate measurement system were self-checked using calibrated light filter before test. The self-check were performed at 100%, 79%, 50%, 32%, 13%, and 0% light transmittance.

#### 3.9.2 Test result

Peak smoke release rate SRR: 0.7136 m<sup>2</sup>/s

Total smoke release TSR: 135.4 m<sup>2</sup>




Figure 16. SRR curve




Figure 17. TSR curve

### 3.10 Gas generation measurement

#### 3.10.1 Test method

The composition, velocity and temperature of the vent gases were measured within the calorimeter's exhaust duct.

Gas composition were measured using a Fourier-Transform Infrared Spectrometer with a resolution of 1 cm<sup>-1</sup> and a path length of 4.2 m within the calorimeter's exhaust duct.

The hydrocarbon content of the vent gas was measured using flame ionization detection.

Hydrogen gas was measured with a palladium-nickel thin-film solid state sensor.

Composition, velocity and temperature instrumentation were collocated with heat release rate calorimetry instrumentation

#### 3.10.2 Total gas release

| Gas type   | Gas components  |                 | Total volume of gas (L) |
|--|-----------------|-----------------|-------------------------|
| Hydrocarbon species  | Methane         | CH <sub>4</sub> | 1.7                     |
| Others   | Carbon Monoxide | CO              | 2.0                     |
|  | Carbon Dioxide  | CO <sub>2</sub> | 10.0                    |
|  | Hydrogen        | H <sub>2</sub>  | 107.1                   |
| Total Hydrocarbons (equivalent to CH <sub>4</sub> , measured by FID) |                 |                 | 17.3                    |

#### 3.10.3 Gas components

Concentration of different gas components were present according to gas species classification in Figures 17 to 22. Average flow rate was 2.55 m<sup>3</sup>/s during test.






Figure 18 Hydrocarbon species


**Figure 19 CO and CO2 concentration**

**Figure 20 Hydrogen**




Figure 21 Total Hydrocarbons

### 3.11 Performance Summary Remark Against Criteria

Installation level testing was not required as the following performance conditions were met during the unit level test.

| Performance conditions  | Remark  |
|---|---|
| a) If flaming outside of the unit observed, separation distances to exposures shall be determine by greatest flame extension observed during test.<br><i>(No flaming)</i>   | No flaming observed in both external and internal of unit during the test.<br>No flaming or charring of the cheesecloth indicating observed.  |
| b) Surface temperatures of modules within the target units adjacent to the initiating unit do not exceed the temperature at which thermally initiated cell venting occurs.  | Surface temperatures of modules within the target units adjacent to the initiating unit was 34.1 °C, which is far below the cell venting temperature 209.4°C (From TUV RH cell 9540A report No.: CN21GRDU 001). |
| c) For units intended for installation near exposures, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient.<br><i>(Temp. measured on wall 1, wall 2 and unit3 surface close to unit 1 shall not exceed 97°C+ambient temp.)</i> | Surface temperature rise measurements on wall surfaces and target unit surface adjacent to unit1 was 5.7°C, far below the 97°C.   |
| d) Explosion hazards are not observed, including deflagration, detonation or accumulation of battery vent gases;<br><i>(The explosion shall not be observed)</i>  | Explosion hazards were not observed in both external and internal of unit, during the test.   |

|   |  |
|---|--|
| e) Heat flux in the center of the accessible means of egress shall not exceed 1.3kW/m <sup>2</sup>                      | No attributable heat flux detected, see clause 3.6 of this report. |
| f) The concentration of flammable gas does not exceed 25% LFL in air for the smallest specified room installation size. | Based on final installation conditions                             |

### 3.12 Photos

See photo documents  
Before the test:



Two units



Three units

During the test:

2023年10月19日 星期四 21:03:09



After the test:  
Units




Initiating module





Damage of the internal components







### 3.13 List of Test and Measurement Instruments

| No. | Equipment   | Model  | Rating  | Inventory no.   | Last Cal. date   |            |
|-----|---|--|---|---|--|------------|
| 1   | Ambient monitor                                   | WSB-2-H1                                       | 0-40°C,<br>10-90%RH                               | S-055   | 2022.07.11   |            |
| 2   | Ambient monitor                                   | WSB-2-H1                                       | 0-40°C,<br>10-90%RH                               | S-050   | 2023.01.03   |            |
| 3   | Ambient monitor                                   | WSB-2-H1                                       | 0-40°C,<br>10-90%RH                               | S-044   | 2023.01.03   |            |
| 4   | Digital multi-meter                               | FLUKE101                                       | 0-600V  | S-038   | 2023.02.08   |            |
| 5   | Tape  | 1000mm<br>5000mm                               | 0-1000mm<br>0-5000mm                              | S-040<br>S-042  | 2022.12.19<br>2022.12.19   |            |
| 6   | Electronic scale                                  | TCS-500  | 0-500kg   | S-039   | 2023.02.09   |            |
| 7   | Charge /ischarge equipment                        | RCDS-100V300A                                  | 100V/300A   | S-045   | 2023.02.08   |            |
| 8   | Heating control equipment                         | DTB4824  | 0-1000°C  | S-060-3   | 2022.07.11   |            |
| 9   | Data acquisition equipment                        | ADAM-4117<br>ADAM-4118<br>MT4W<br>MT4W<br>DTM  | 0-10V<br>0-1000°C<br>0-100V<br>0-500V<br>0-1000°C | S-060-1<br>S-060-2<br>S-060-4~5<br>S-060-6~7<br>S-061 | 2022.07.11<br>2022.07.11<br>2022.07.11<br>2022.07.11<br>2022.07.11 |            |
| 10  | Oxygen consumption calorimeter measurement system | Paramagnetic oxygen analyzer                   | OXYMAT 61   | O2:0-21%  | S-024-09   | 2022.08.11 |
|     |   | CO and CO2 sensor                              | ULTRAMAT 23                                       | CO2:0-10%<br>CO:0-1%                                  | S-024-08   | 2022.08.11 |
|     |   | Micro-differential pressure transmitter (20MW) | DP101MD   | -100~100Pa  | S-024-4  | 2023.02.08 |
|     |   | Thermopile (20MW)                              | TTI20-CAXL-II<br>6U-10-SPW-M                      | 0~200°C   | S-024-1~3  | 2023.01.03 |
| 11  | Palladium-nickel thin-film solid state sensor     | 710B   | 0.05%~100%  | S-023-1   | 2022..08.11  |            |
| 13  | Electrochemical hydrogen sensors                  | H <sub>2</sub> -2000/H <sub>2</sub> -40000     | 0~0.2%/0~4%                                       | S-023-2~3   | 2022.08.11   |            |
| 14  | Fourier-Transform Infrared Spectrometer           | MG6000   | 0.01ppm-100%                                      | S-019   | 2023.01.30   |            |
| 15  | Flame Ionization Detector                         | AO2040   | 0-30000mgC/m <sup>3</sup>                         | S-025-1   | 2022.08.11   |            |

**Prüfbericht - Nr.: CN23AYBH 001**  
Test Report No.:

Seite 38 von 38  
Page 38 of 38

|    |                                 |         |        |         |            |
|----|---------------------------------|---------|--------|---------|------------|
| 16 | Heat flux measurement equipment | 64-5-20 | 0-50kW | S-031-1 | 2022.06.10 |
|    |                                 |         |        | S-031-2 | 2022.06.10 |
|    |                                 |         |        | S-031-3 | 2022.06.10 |
|    |                                 |         |        | S-031-4 | 2022.09.09 |
|    |                                 |         |        | S-031-5 | 2022.06.10 |
|    |                                 |         |        | S-031-6 | 2022.06.10 |
|    |                                 |         |        | S-031-7 | 2021.09.09 |
|    |                                 |         |        | S-031-8 | 2021.09.09 |

**End of Test Report**